Mob. : 9343577...

# HARSHA BOREWELLS

7", 6", 6½", Drilling Agency

D. Cross, Dr. Raj Circle, Ramamurthy Building, Doddaballapur-561203. Bangalore Dist.

## WORK COMPLETION REPORT

No. 06

Date :.....

Name : B.B.M.P -

Address : Chowdeshwari ward no-02.

Location : Kondappa L/o 11th Cross -

Drilling Depth : 326.50 mtr

MS Casing Depth : 424 mtr

10" PVC : 17 mtr

Welding Joints :

Boulders / Silit : Yes

No. Collers : 7 @ NO

Yield Details : Oil

Asst. Executive Engineer
Yelahanka Sub. Divison
(BBMP Ynk. Zn)
Yelahanka, Bangalore

Paty Signature

For Harsha BoreWells

Manager / Proprietor

# HARSHA BOREWELLS

7", 6", 6½", Drilling Agency

D. Cross, Dr. Raj Circle, Ramamurthy Building, Doddaballapur-561203. Bangalore Dist.

## WORK COMPLETION REPORT

No. 05

Date :.....

Name : B.B.M.P.

Address : Chowdeshwari ward no-02.

Location : Kamakshama L/o main road near Telugu school

Drilling Depth : 316 mtrs

MS Casing Depth : 30.50 mtrs

10" PVC : 15 mtrs

Welding Joints : 7

Boulders / SIlit : Yes

No. Collers : 6

Yield Details : 2.5"

Asst. Executive Engineer
Yelahanka Sub. Divison
(BBMP Ynk. Zn)
Yelahanka, Bangalore

Paty Signature

For Harsha BoreWells

Manager / Proprietor

9343377088 Mob : 9591907788

# HARSHA BOREWELLS

7", 6", 6½", Drilling Agency
D. Cross, Dr. Raj Circle, Ramamurthy Building, Doddaballapur-561203. Bangalore Dist.

## WORK COMPLETION REPORT

No. 04 Date :.....

Name : B.B.M.P.

Address : Chowdeshwari ward No-02 -

Location : Kamakshamma L/out road opp new Railway Station

Drilling Depth : 320 mtrs

MS Casing Depth : 56 mtrs

10" PVC : 16 mtrs

Welding Joints : 10

Boulders / Sllit : Yes

No. Collers : 9

Yield Details : Fail

Asst. Executive Engineer
Yelahanka Sub. Divison
(BBMP Yne. Zn)
Yelahanka, Bangalore

Paty Signature

For Harsha BoreWells

Manager / Proprietor

9343377880
Mob : 9591907788

# HARSHA BOREWELLS

7", 6", 6½", Drilling Agency
D. Cross, Dr. Raj Circle, Ramamurthy Building, Doddaballapur-561203. Bangalore Dist.

## WORK COMPLETION REPORT

No. 03

Date :.....

Name : B.B.M.P -

Address : Chowdeshwari ward no-02 -

Location : Kamakshamma H/o 15th main road forward new Railwaystation

Drilling Depth : 325 mtrs

MS Casing Depth : 33 mtrs

10" PVC : 15 mtrs

Welding Joints : 8

Boulders / Sllit : Yes

No. Collers : 7

Yield Details : 2' 0"

Asst. Executive Engineer
Yelahanka [illegible] Division
(BBMP [illegible] Zone)
Yelahanka, Bangalore

Paty Signature

For Harsha BoreWells

Manager / Proprietor

## GROUND WATER SURVEY REPORT

~~OPEN WELL / BOREWELL~~
DATA OF SURVEY

a) Name of the Party : BWell no 12

b) Location of the Site : 18th Main Ramakrishnappa

c) Area of the land : yellow

### INVESTIGATION REPORT

1) GEOLOGY OF THE AREA : Gneiss-granite

2) Recommended Site for drilling : W1
3) Total depth to be drilled : 1200'-1300'
4) Approx. casing pipe required : 135'-140'
5) No. of water bearing Zones : -4-
6) No. of favorable spots marked : -1-
7) Qty. of water expected : 2 lit-3 lit
8) Method of survey carried out : Fractured
9) Remarks : 6½" dia Bored well-W1

Asst. Executive Engineer
Yelahanka Sub. Division
Yelahanka, Bangalore

P.T.O. : Terms & Conditions

HYDROGEOLOGIST
(M.G. RAJASHEKHAR, M.Sc., DEG., F.G.S.)

BOREWELL SITE PLAN



## GROUND WATER SURVEY REPORT

~~OPEN WELL~~ / BOREWELL
DATA OF SURVEY

a) Name of the Party : [illegible]

b) Location of the Site : Nondappa Layout

c) Area of the land : Main Rd, New Tehsil School

### INVESTIGATION REPORT

1) GEOLOGY OF THE AREA : Granite gneiss

2) Recommended Site for drilling : W11
3) Total depth to be drilled : 1200'-1300'
4) Approx. casing pipe required : 130'-140'
5) No. of water bearing Zones : —"—
6) No. of favorable spots marked : —"—
7) Qty. of water expected : 2½"-3"
8) Method of survey carried out : Dowsing
9) Remarks : 6½" dia Bullet - W1

P.T.O. Terms & Conditions

HYDROGEOLOGIST
(M.G. RAJASHEKHAR, M.Sc., DEG., F.G.S.)

BOREWELL SITE PLAN



## GROUND WATER SURVEY REPORT

~~OPEN WELL~~ / BOREWELL
DATA OF SURVEY

a) Name of the Party : BBMP/Ward No. 2

b) Location of the Site : Kodigehalli Main Rd

c) Area of the land : 9M to New Lay Out

### INVESTIGATION REPORT

1) GEOLOGY OF THE AREA : Granite gneiss terrain

2) Recommended Site for drilling : W1

3) Total depth to be drilled : 1200'-1300'

4) Approx. casing pipe required : 130'-140'

5) No. of water bearing Zones : — 4 —

6) No. of favorable spots marked : — 1 —

7) Qty. of water expected : 2"-3"

8) Method of survey carried out : Rotary

9) Remarks : 6½" dia Bit at W1

Asst. Executive Engineer
Yelahanka Sub. Divison
(BBMP Ynk. Zn)
Yelahanka, Bangalore

P.T.O. : *Terms & Conditions*

HYDROGEOLOGIST
(M.G. RAJASHEKHAR, M.Sc., DEG., F.G.S.)

BOREWELL SITE PLAN



## GROUND WATER SURVEY REPORT

~~OPEN WELL~~ / BOREWELL
~~DATA~~ OF SURVEY

a) Name of the Party : BBMP Ward 12

b) Location of the Site : Hondegere Main Rd

c) Area of the land : Yelahanka,

### INVESTIGATION REPORT

1) GEOLOGY OF THE AREA : Granite, Gneiss

2) Recommended Site for drilling : W1

3) Total depth to be drilled : 1200 - 1300'

4) Approx. casing pipe required : 130' - 140'

5) No. of water bearing Zones : — 4 —

6) No. of favorable spots marked : — 1 —

7) Qty. of water expected : 2 - 3 lpm

8) Method of survey carried out : Fracture method

9) Remarks : 6½" Dia Bullet W1

Asst. Executive Engineer
Yelahanka Sub. Division
(BBMP Ynk. Zn)
Yelahanka, Bangalore

HYDROGEOLOGIST
(M.G. RAJASHEKHAR, M.Sc., DEG., F.G.S.)

*P.T.O. : Terms & Conditions*

BOREWELL SITE PLAN